



BANGALORE TEST HOUSE

65, 20th Main, Marenahalli, Vijayanagar, Bangalore - 560 040.
Ph.: 23356415, 23151665, Fax: 080-23385979
e-mail: testhouse@satyam.net.in website: www.bthindia.com



TEST REPORT


Page : 1 of 1


Report No. : ED/2013/04/0273	Report Date : 17/04/2013
Issued to : G-Corp Homes Pvt Ltd	Customer Reference: Letter, Dated: 13/04/2013
The ICON Project, Thanisandra Main Road, Thanisandra, BANGALORE - 560 077.	Date of Receipt : 13/04/2013
	Date of Start of Test : 15/04/2013
	Date of Completion of Test : 17/04/2013
Sample Nature/ Name : Treated Filter Water	Job Order No. : ED/2013/04/0273
Sample Condition : Satisfactory	Sample Particulars : Treated Filter Water for Our Project The ICON at Thanisandra, Thanisandra Main Road, Bangalore -

SL. No.	PARAMETERS	RESULTS	ACCEPTABLE LIMITS AS PER IS: 10500-1991 (Amd.3)	PROTOCOL
	Description	Colourless and clear transparent liquid filled in sterilised bottle.		
	MICROBIOLOGICAL TESTS:			
1	Coliform Organisms / 100ml	Less than 1	Less than 1	IS: 1622 - 1981
2	E. coli Bacteria / 100ml	Absent	Absent	IS: 1622 - 1981

Remarks : The sample conforms to IS: 10500-1991 for drinking water with respect to Microbiological Requirements.


ANALYST


264


AUTHORIZED SIGNATORY

NOTE : 1. The result listed refer only to the tested samples & applicable parameters. Endorsement of products is neither inferred nor implied. 2. Samples will be destroyed after 15 days from the date of issue of test certificate unless otherwise specified. 3. This report is not to be reproduced wholly or in part & cannot be used as an evidence in the Court of law & should not be used in any advertising media without our special permission in writing. 4. Sample(s) not drawn by us unless otherwise stated. 5. Total liability of our laboratory is limited to the invoice amount. Any dispute arising out of this report is subject to Bangalore Jurisdiction only.